

WEST MORRIS REGIONAL HIGH SCHOOL DISTRICT

ADMINISTRATION BUILDING
CHESTER, NEW JERSEY 07930

•10 SOUTH FOUR BRIDGES ROAD
•908-879-6404 Fax: 908-879-8861

January 5, 2022
SECRETARY

L. DOUGLAS PECHANEC
BUSINESS ADMINISTRATOR / BOARD

To the West Morris Central High School District Community:

We are providing the following documents as an update to the recent lead testing of West Morris Central High School.

- Initial notification letters - [WM Central](#)
- [Complete testing/flushing report](#) - provided by Precision Analytical Services, Inc.

We tested 29 fixtures at WM Mendham. The initial report indicated elevations above the PPB, Parts Per Billion, the EPA "Action Level" for a first draw sample, in 1 location within the Building. We immediately took the water fixture out of service. Subsequently, we received the flushing report indicating that all fixtures that were above 15.5 PPB in the first sampling after the flushing process, (i.e. run water for 30 seconds or more) were **below** 15.5 PPB.

Our next steps will be to take remedial actions to ensure that water quality throughout our facilities is safe for all.

Sincerely,

L. Douglas Pechanec